


ACCAM S.P.A.


REPORT LINEA 1 GENNAIO 2016						
Data	NOx	SO ₂	HCl	CO	PLV	NH ₃
	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>
	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>
1	82,1	3,9	0,58	2,3	0,74	1,66
2	73,5	4	0,01	3,4	0,79	1,59
3	74,4	0,9	0	3,9	0,47	1,65
4	74,4	5,6	0	2,8	0,95	1,64
5	78	1,9	0	2,8	0,84	1,61
6	73,4	1,6	0	2,7	0,98	1,7
7	67,3	0,8	0	3	0,69	1,46
8	69,4	3	1,18	3,2	0,9	1,29
9	68,4	0,7	0,09	4,9	1,04	1,29
10	66,5	2,3	0,28	5,2	1,25	1,31
11	94,8	7,8	0	1	1,27	1,03
12	94,8	12,4	0,33	0	1,45	0,98
13	100,1	11,2	0	0	1,37	0,99
14	73,3	7,2	0	3	1,53	1,13
15	56,6	5	1,72	5,5	1,72	2,43
16	63,8	5,1	1,44	6,5	1,94	2,21
17	73,9	1,9	0,3	6,1	2,28	2,1
18	62,3	2,1	0	5,4	2,81	1,76
19	70,6	5,8	0,53	4,1	2,68	1,86
20	69,2	5,6	0,15	4,1	2,58	1,89
21	70,5	4,3	0,03	4,9	2,07	1,67
22	91,4	11,8	0,01	1	1,6	1,17
23	99,9	16,9	0	0	1,45	1,03
24	99,3	19,7	0	0	1,66	1,03
25	103,5	18,8	0	0	2,31	1,05
26	96,7	19,9	0	0	2,79	1,03
27	78,3	13,7	0	1,2	3,21	1,13
28	66,2	5,6	0,01	2,5	3,64	1,42
29	82,8	12,9	0	1,1	4,42	1,13
30	79,1	17,1	0	1,1	5,02	1,16
31	72,7	16	0	1,8	7,46	1,14
media	78,30	7,92	0,21	2,69	2,06	1,44
Limiti	120	50	10	50	10	30



ACCAM S.P.A.

REPORT LINEA 2 GENNAIO 2016						
Data	NOx	SO ₂	HCl	CO	PLV	NH ₃
	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>	<i>mg/Nm3</i>
	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>	<i>media giorn.</i>
1	91,9	7,9	0,11	0	0,78	1,63
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29	75,7	10,1	1,92	1,8	0,71	2,08
30	77,9	8,9	4,38	1,8	0,74	2,19
31	84,8	2,9	3,32	1,7	0,73	2,14
media	82,58	7,45	2,43	1,33	0,74	2,01
Limiti	120	50	10	50	10	30

LINEA FERMA PER MANUTENZIONE



ACCAM S.P.A.

